

**Final Report
Project Cost Estimate Peer Review of
Microfiltration Supplemental Technology
Demonstration Project**

Prepared by:

**PB Water, a division of Parsons Brinckerhoff Quade &
Douglas, Inc.**

In association with:

Milian, Swain & Associates, Inc.

Prepared for:

**South Florida Water Management District
Everglades Construction Project**

May 7, 2001

Table of Contents

<u>Title</u>	<u>Page</u>
Executive Summary	4
Section 1.0 – Project Purpose	5
1.1 Kickoff Meeting	
1.2 Peer Review Team	
1.3 Reference Material	
Section 2.0 – Background	6
2.1 History	
2.2 Future Phases	
2.3 Microfiltration Supplemental Technology Demonstration Project	
2.4 HAS Report Update – Project Objectives	
Section 3.0 – Peer Review	12
3.1 Proprietary Systems	
3.2 Indirect Costs not Related to Membrane Filtration	
3.3 Cost Differences – Pilot Test versus Currently Available Products	
3.4 HSA's Updated Cost Estimates for Full-Scale Implementation	
3.5 MF versus UF Costs	
3.6 Capital Costs	
3.7 Capital Cost Curves	
3.8 Operation and Maintenance Costs	
3.8.1 Labor Costs	
3.8.2 Spare Parts	
3.8.3 Coagulant Costs	
3.8.4 Energy Costs	
3.9 Membrane Replacement	
3.10 Total Annual Operating Cost	
3.11 Industry Trends	
3.12 Residuals Management	
3.13 Conclusions	
Appendix A	A-1 through A-15

Executive Summary

PB Water, a division of Parsons Brinckerhoff Quade & Douglas, Inc., and Milian Swain & Associates, Inc. (PB Team), under District Contract C-E018, were tasked to review and comment on the membrane related costs (capital and O&M) contained in the updated report by HSA Engineers & Scientists, Inc. In addition, the scope included a request to comment on current MF/UF membrane technology as it relates to capital and O&M costs and a discussion on residuals management.

Conestoga-Rovers & Associates, Inc. (CRA) completed the “Microfiltration Supplemental Technology Demonstration Report” in May 1998. The report was updated in January 2001 by HSA Engineers & Scientists, Inc. (HSA), who is CRA’s successor company in Florida. The following are criteria and findings of this effort:

- ❑ The basis for costs, both in the HSA report and this report, is the membrane manufacturer (Memcor and Zenon).
- ❑ Zenon no longer manufactures the MF membrane tested by CRA in the original study and only offers a UF module in the submerged configuration.
- ❑ The Zenon membrane cost from the updated report was based on a different (UF with higher square footage per module model) membrane than was originally tested.
- ❑ The Memcor membrane cost from the updated report was based on a different (both composition and flux rate) membrane than was originally tested and Memcor now recommends a submerged configuration of its MF polypropylene membrane
- ❑ The Memcor costs in this report are based on US Filter-Memcor’s polypropylene submerged CMF-S technology, which is the same material composition as the CRA tested module but in a submerged configuration.
- ❑ The Zenon costs are for the same membrane as described in the HSA updated report.

The following are conclusions and recommendations of this effort:

- ❑ The updated capital and O&M cost estimates by HSA are sufficient for the engineering budgetary cost estimate because the accuracy range is within +30% to –15%, which is in accordance with the American Association of Cost Engineers
- ❑ The PB Team recommends that the District use the latest capital and O&M cost curves developed for this report for the US Filter-Memcor CMF-S Submerged membrane system, when comparing MF to other processes.
- ❑ The PB Team concurs with HSA’s assessment that local land spreading of residuals appear to be the most cost effective disposal method for the MF Process.
- ❑ Because of the proprietary nature of membrane manufacturing, the PB Team recommends that alternative delivery methods be investigated to assure long-term performance and membrane availability.

1.0 Project Purpose

The purpose of the project was to peer review Chapter 5 of the updated report titled *Microfiltration Supplemental Technology Demonstration Project*, HSA Engineers & Scientists, January 2001 as it relates to capital and O&M membrane process costs and to provide a discussion on residuals management.

1.1 Kickoff Meeting

A kick-off meeting was held on Tuesday, January 30, 2001 from approximately 1:00 PM to 3:00 PM at the District's offices at 3301 Gun Club Rd., West Palm Beach, Florida. The meeting was arranged by District staff to initiate the peer review. In addition to District staff, the meeting was attended by consultants from HSA, PB Water, and Milian Swain & Associates, Inc. (MSA). During the meeting, HSA presented an overview of their methodology used to arrive at the updated capital and O&M costs (Chapter 5).

1.2 Peer Review Team

The PB Peer Review Team consisted of William J. Conlon, P.E., DEE, Technical Manager, PB Water and Robert Regalado, Senior Engineer, Milian, Swain & Associates, Inc.

1.3 Reference Material

The following materials were used in the preparation of this document:

- HSA Engineers & Scientists, Inc., *"Microfiltration Supplemental Technology Demonstration Project,"* May 1998, updated January 2001
- *Project Peer Review Guidelines*, American Consulting Engineers Council, American Society of Civil Engineers, 1990
- PEER Consultants, P.C./Brown and Caldwell Consultants, *"Desktop Evaluation of Alternative Technologies,"* Final Report under SFWMD Contract No. C-E008, Amendment 3, August 1996.
- PEER Consultants, P.C./Brown and Caldwell Consultants, *"Basis for Cost Estimates of Full Scale Alternative Treatment (Supplemental) Technology Facilities,"* Contract C-E008-A12, August 1999.
- HSA Engineers and Scientists (former CRA) *"Chemical Treatment Followed by Solids Separation Advanced Technology Demonstration Project"* documents under Contract C-E10650:
 - Operations Management Plan, May 1999.
 - CT-SS Project Update for Period November 12- December 31, 1999- January 21, 2000.
 - Final Report Draft- May 2000.
- *Full Scale Design and Cost Estimate Peer Review Report* prepared by Parsons Brinckerhoff and Hazen and Sawyer, August 2000.

2.0 Background

2.1 History

Florida's 1994 Everglades Forever Act (F.S. 373.4592) and the federal Everglades Settlement Agreement (Case No. 88-1886-CIV-HOEVELER) establish both interim and long-term water quality goals designed to restore and protect the Everglades Protection Area (EPA). As defined in the Act and the Settlement Agreement, the Everglades Protection Area includes Water Conservation Areas 1, 2A, 2B, 3A, 3B, the Arthur R. Marshall Loxahatchee National Wildlife Refuge, and the Everglades National Park.

Activities are currently underway to meet the interim goal of reducing phosphorus levels in discharges from the Everglades Agricultural Area (EAA) and other sources to the Everglades Protection Area to a long-term annual flow-weighted mean concentration of 50 parts per billion (ppb). These activities include the implementation of Everglades Agricultural Area Best Management Practices (BMPs) and the construction of over 42,000 acres of Stormwater Treatment Areas (STAs) through the Everglades Construction Project (ECP). Concurrent with implementation of the ECP, the District is implementing the Everglades Stormwater Program (ESP) to address the water quality issues associated with discharges from the remaining non-ECP Everglades tributary basins. Also concurrent with these activities, the District and other groups are conducting water quality research, advanced treatment technology research, ecosystem-wide planning (e.g., the Comprehensive Everglades Restoration Plan, or CERP), and regulatory programs to ensure a sound foundation for science-based decision making.

The long-term goal of the Everglades Program restoration effort is to combine point source control, basin-level and regional solutions in a system-wide approach to ensure that all waters discharged into the Everglades Protection Area meet the numeric phosphorus criterion and other applicable state water quality standards by December 31, 2006.

In accordance with the Act, the EPA total phosphorus (TP) criterion shall be 10 ppb in the event the Florida Department of Environmental Protection (DEP) does not adopt by rule such criterion by December 31, 2003. The Corps of Engineers Permit for the Everglades Construction Project requires "For the purposes of planning, 10 ppb (total phosphorus) shall be used as the design parameter pending adoption of the numeric criterion by the Department of Environmental Protection or Everglades Regulatory Commission."

The District and other parties are engaged in the research and demonstration of Advanced Treatment Technologies (ATTs) that may be used alone or in conjunction with STAs for achieving the long-term water quality goals of the Everglades. Research teams are evaluating the technical, economic and environmental feasibility for basin-scale application.

Eight ATTs are being evaluated:

1. Chemical Treatment- Direct Filtration
2. Chemical Treatment- High Rate Sedimentation
3. Chemical Treatment- Dissolved Air Flotation/Filtration (DAF)
4. Chemical Treatment- Microfiltration
5. Low Intensity Chemical Dosing of Wetlands (LICD)
6. Managed Wetlands

7. Submerged Aquatic Vegetation (SAV)/Limerock
8. Periphyton-based Stormwater Treatment Areas (PSTAs)

As a result of the research studies conducted during 1998 and 1999, Chemical Treatment- Direct Filtration, Chemical Treatment- Dissolved Air Flotation/Filtration and Low Intensity Chemical Dosing of Wetlands did not achieve the 10 ppb TP goal, and are not considered viable technologies for this Statement of Work.

To enable the District to provide a scientifically defensible basis for comparative evaluation of the successful technologies, a Supplemental (Advanced) Treatment Technology Standard of Comparison (STSOC) was established. The STSOC provides an approach to comparing the effectiveness of one advanced treatment technology to another. The STSOC has evolved as follows:

- | | |
|------------|--|
| Phase I: | Formulate conceptual approach and the development of the Contract Guidance Documents |
| Phase II: | Development of the evaluation methodology and an STSOC database |
| Phase III: | Development of standardized cost information |
| Phase IV: | Compilation and evaluation of Advanced Treatment Technology data |

In Phase I, Peer Consultants prepared a concept letter report that proposed twelve evaluation concepts and a Contract Guidance Document (PEER Consultants, P.C./Brown and Caldwell, 1998a). This Contract Guidance Document listed the goals and detailed the specific information on sampling, data management protocol, forms, and formats that each of the Advanced Treatment Technology Demonstration Project Research Teams (DPRTs) needed to follow during data collection.

In Phase II, Peer Consultants refined the evaluation concepts into an evaluation methodology consisting of 10 criteria. The evaluation methodology attempts to provide a basis to compare dissimilar technologies. An STSOC database was developed to serve as a repository for storing DPRTs' research data and as a comparative ATT evaluation tool. The evaluation methodology for the data and information collected from the DPRTs consisted of quantitative and qualitative concepts and are set forth below.

Quantitative Evaluation Methodology

1. Level of Phosphorus Concentration Reduction
2. Level of Phosphorus Load Reduction
3. Cost-effectiveness
4. Potential toxicity
5. Implementation schedule

Qualitative Evaluation Methodology

1. Uncertainty Assessment of Full Scale Construction, Operations, and Scale-up
2. Operational flexibility
3. Sensitivity to fire, flood, drought and hurricane
4. Level of effort to manage side streams control
5. Other water quality issues

During Phase III, PEER Consultants/Brown and Caldwell developed standardized costing data to serve as the basis for estimating the cost of equipment, land, levees, etc. to be used by each DPRT in developing full-scale treatment facilities. The cost basis will be used with the evaluation guidelines established in previous documents for Phases I and II to make comparisons between the technologies.

2.2 Future Phases

During Phase IV, which is scheduled to be complete within the next two years, data from the ATT projects will be compiled, evaluated and compared.

One of the final deliverables from the demonstration project research teams will be a report summarizing the research results, including a conceptual-level layout of a full-scale treatment system designed to treat the flows and phosphorus loads into and out of STA 2 for the period 1979-1988 (Period of Record or POR). Conceptual estimates of capital and annual operation and maintenance costs will be included in this report, as will preliminary implementation schedules.

Due to the unique nature and anticipated magnitude of the application of these Advanced Treatment Technologies, the District intends to facilitate peer draft final report for each viable technology, by qualified firms, independent from District staff review efforts.

2.3 Microfiltration Supplemental Technology Demonstration Project

The Microfiltration (MF) Demonstration Project conducted by CRA was the initial supplemental technology to be field tested as part of the EFA defined Superior Technology Demonstration Program. The EPA-319 H Grant Program and the District provided primary funding for the project. The Sugar Cane Growers Cooperative of Florida and CRA provided additional project funding. The Florida Department of Environmental Protection (FDEP) served as the contracting agency for the MF Study and CRA received their notice to proceed under FDEP Contract Number WM 640 on July 26, 1996.

The final MF report was completed by CRA in May of 1998, and was submitted to the FDEP at that time. The final report summarized the results of the year-long study and field investigations which commenced in September of 1996 and were completed at the end of August 1997. The CRA report also provided a full-scale conceptual design and cost estimate for constructing 200 mgd and 175 mgd MF treatment systems for post-BMP and post-STA applications, respectively.

As previously stated, the original research and final report phases of this MF demonstration project was completed by the engineering consulting firm of CRA in 1998. On October 1, 1999, CRA signed an agreement with HSA under which CRA's operations in the State of Florida were merged with HSA's existing technical service hubs. Since this time, CRA's full-service engineering and environmental staff and resources located within the State of Florida are currently working under the name of HSA Engineers & Scientists, Inc., a member of the CRA family of companies.


The cost estimate for the full-scale MF system was prepared by CRA in terms of 1998 dollars, and the report was completed prior to SFWMD finalizing their Standard of Comparison procedures that were to be utilized for evaluating the Advanced Treatment Technologies. In addition, advancements to membrane technology processes have occurred during the last several years that have improved the technology and, in certain applications, have reduced associated capital and O&M costs. The revised report by HSA updated the costs of the full-scale MF treatment system originally provided in the 1998 report, and describes industry advances during the last two years in membrane technology that may result in capital or operational cost savings or improved system performance.

This peer review effort evaluated the cost update completed by HSA and included cost changes that have occurred within the last few months since their report was completed. In addition, the MF membranes pilot tested by CRA either are no longer US Filter-Memcor's membrane of choice for this application or in the case of Zenon are no longer manufactured as MF membranes. The updated cost estimate by HSA for Zenon's membrane was based on their model 500C ZeeWeed® membrane which is now classified as a UF membrane. Zenon reports they no longer manufacture MF membranes in the ZeeWeed® configuration.

The Zenon ZeeWeed® membrane now offered is an UF membrane. The MF-150 membrane had an absolute pore size of 0.2 microns, as did the Memcor MF membrane. In the transition to the manufacture of UF membranes exclusively, Zenon offered a predecessor to the MF-150 membrane with pore size range of 0.2 to 0.08 microns, which was also discontinued. The latest Zenon ZeeWeed® UF membrane is designated as model 500C with pore sizes ranging between 0.04 and 0.1 microns.

By definition, microfiltration is the separation of micron or sub-micron particulate matter in solution across a membrane material. In general, the lowest pore size for a commercially available (scaled-up for municipal use) MF membrane is approximately 0.2 microns absolute such as is the US Filter-Memcor polypropylene and the discontinued Zenon MF-150 ZeeWeed® membranes tested.

MF membranes are “absolutely” rated. The terminology “absolute” means 100% retention of the particles of the size equal to the filter rating. A nominal rating on the particle size retention curve (size of particles challenging the membrane versus the percent of particles rejected) exists where most of the particles are retained. In the MF process, usually 100% of the feed stream is recovered. UF membranes are rated both absolute and nominal. Figure 1 that follows illustrates the MF and UF membranes particle size ranges:



Particle size separation comparison chart (Courtesy of Basic Technologies, Inc.)

Figure 1

2.4 HAS Report Update – Project Objectives

The original study objectives included assessing the pilot testing/feasibility study of the MF technology at the Everglades Nutrient Removal (ENR) Project, evaluating the performance of the MF pilot unit under variable flow rates, and varying influent phosphorus concentrations.

As part of the demonstration of the effectiveness of MF, an analytical comparison was made between influent and effluent data collected from the MF Pilot unit to assess potential removal effectiveness with and without chemical addition. Additionally, a comparison of a surface water influent to, and effluent from, the MF unit was performed based on the results of toxicity bioassays and Algal Growth Potential (AGP) analyses.

In order to update the 1998 MF system full-scale cost estimates, assess the membrane process technology advancements, and prepare a membrane study summary in the format specified by the Standard of Comparison, the updated report was prepared in January 2001.

Inclusion of additional specific objectives included:

- HSA consulted with MF/UF manufacturers (US Filter-Memcor, X-Flow, Zenon, and others) in order to update potential advances in the MF processes and to determine the current status of the technology as it applies to treating EAA stormwaters.

- Using the format identified in the Supplemental Technology Standard of Comparison (STSOC) (PEER Consultants/Brown and Caldwell, 1999), HSA updated the full-scale post-BMP and post-STA cost estimates provided in CRA's 1998 MF final report. Unit prices and cost curves specified in the STSOC were used to prepare the cost update.
- Comparison of analytical test parameters, flow measurement techniques, and sample compositing techniques, as well as other protocols listed in the STSOC, with those completed during the CRA MF Study (conducted prior to STSOC report completion). Data gaps and the effect of missing data were summarized in the final report.

3.0 Peer Review

3.1 Proprietary Systems

Both the US Filter-Memcor MF and the Zenon ZeeWeed® UF membrane processes are proprietary membrane systems. Both processes are separate and distinct patented processes. Proprietary systems are designed as “black box” systems by the manufacturer (not by the consulting engineer) and render the purchaser operationally dependent on the manufacturer for replacement membranes and certain equipment parts. It is anticipated that at some time in the future MF and UF membranes will be standardized similarly to the evolution of the reverse osmosis industry’s spiral wound eight-inch elements.

Only the membrane manufacturer can issue quotes for accurate prices of their capital equipment and associated O&M costs. These costs are constantly changing due to market demand, competition, cost of materials, and improvements to the membranes, membrane devices and their appurtenances. The general trend for overall membrane system costs has been downward. However, certain changes have occurred since the updated report was completed in January 2001 that has impacted cost and is reflected in this report. Estimated membrane costs in this document were developed through numerous telephone conversations with the manufacturer.

Appendix A contains a description of the current, as of this publication, processes for Memcor and Zenon.

3.2 Indirect Costs not Related to Membrane Filtration

PEER Consultants/B&C developed standardized costing data, which are periodically updated by the District to serve as the basis for estimating the cost of equipment, land, levees, etc. to be used by each department in developing full-scale treatment facilities. This cost basis will be used with the evaluation guidelines established in previous documents for making comparisons between this and other technologies. These costs were not evaluated as part of this effort because the focus was to review the capital and O&M costs related to membrane processes.

3.3 Cost Differences – Pilot Test versus Currently Available Products

The membranes pilot tested during the preparation of the CRA report have changed either in configuration, membrane composition, membrane technology, or operating mode; and, those cost variations should be evident in the differences in the original CRA report, the HSA update and this report.

For example, the Zenon MF-150 (450 sq. ft.) series membrane module (then clearly identified as a MF membrane) pilot tested by CRA now contains 650 sq. ft. of membrane area and is now an UF membrane. The submergence tanks are now aerated on a cyclic basis. The Zenon membrane pilot tested is a “tighter” membrane now than when pilot tested and is clearly identified by Zenon as a UF membrane.

The US Filter-Memcor hollow fiber polypropylene membrane demonstrated by CRA was then only available in the totally enclosed cartridge configuration (CMF) operational mode. The only Memcor MF membrane material then proven and available from US Filter-Memcor was of the polypropylene hollow fiber material. These same polypropylene membranes are not chlorine or oxidant resistant. Since then a chlorine resistant membrane, demonstrating a lower flux per unit area, consisting of PVdf material is available either in cartridge or submerged configuration. The PVdf membrane material was not considered as part of this effort because of the following:

- ❑ higher cost;
- ❑ lower flux;
- ❑ no large plants using the PVdF membranes; and
- ❑ polypropylene was the membrane material CRA pilot tested.

Polypropylene CMF-S submerged technology is now recommended by the manufacturer for this application and for large plants of the sizes under consideration.

3.4 HSA's Updated Cost Estimates for Full-Scale Implementation

HSA's updated costs were based on US Filter's MF PVdf submerged membranes and the latest model Zenon ZeeWeed® UF submerged membranes. US Filter-Memcor stated they would recommend their submerged polypropylene membranes over their submerged PVdF membranes for this application due to their higher flux, smaller footprint and resultant lower cost.

The updated report indicated that membrane cost estimates were developed from equipment supplier quotations and prior engineering experience. This effort also utilized capital and O&M cost estimates based on current information supplied by the manufacturers.

In the cost update report, HSA stated “the testing proved that the Memcor (US Filter) and Zenon pilot systems performed comparable with respect to phosphorus removal and flux restoration. Both suppliers provided capital and operational costs. The full-scale updated cost data provided by Zenon were slightly lower than those provided by US Filter-Memcor, and therefore, the 12 full-scale facility estimates are based on the Zenon MF (now UF) system. This is not necessarily an endorsement of one vendor, but an engineering judgment to provide the lowest representative costs for the full-scale facilities.”

The Peer Review Team agrees that the test results for the Memcor CMF and Zenon MF pilot systems were comparable. The updated cost information supplied to HSA by Zenon was for UF membranes, not MF. US-Filter-Memcor's updated cost information was based on a PVdf membrane. Neither of these membranes was pilot tested by CRA. Nevertheless, the updated cost estimates provided by HSA are within acceptable limits of the latest costs obtained by the Peer Review Team.

In addition, Zenon's cost estimates to both HSA and the Peer Review Team were based on using the latest 650 square foot or 500C UF membranes. According to HSA, currently Zenon is introducing a new membrane design, model ZW-1000, which is being pilot tested at several locations. However, these new generation membranes are UF membranes for clean water applications only. The main advantage of these membranes for clean water applications is a

reduction in system footprint, as well as a reduction in operational cost for power consumption and chemical requirements for membrane cleaning.

3.5 MF versus UF Costs

There will be inherent capital and O&M cost differences in trying to compare these two proprietary membrane processes on an “apples to apples” basis. If the District desires solely MF costs for comparison to other processes, the US Filter-Memcor CMF-S costs should be used. The capital costs will vary between the processes because of differences:

- ❑ in manufacturers pricing structures based on market demand;
- ❑ due to manufacturer’s component country of origin (Canada, Australia, USA, etc.);
- ❑ cost to manufacture system components;
- ❑ in process footprints for MF/UF processes membrane material; and
- ❑ degree of instrumentation and control.

UF operational costs will be different than MF O&M costs since the UF membrane is a finer filter and a heavy molecular weight separations process. Fewer chemicals with less sludge generated may be an advantage whereas, due to the smaller pore size, increased fouling may occur and require more frequent cleaning. Pilot testing of the new generation Zenon UF membrane would be required to yield more accurate O&M cost comparisons.

3.6 Capital Costs

The capital costs were strictly considered for process specific equipment, as follows: membranes, membrane tanks, frames, support beams, permeate pumps, backpulse pumps, air scour blowers, PLCs and MCC, permeate and air scour headers, backpulse chemical feed system, CIP chemical feed systems, reject pumps, and turbidity and particle counters. These costs were established through conversations with the manufacturer/supplier. HSA’s capital cost estimates obtained from Zenon are shown in Table 5.9 of the updated report. The capital costs reflected within the following curves are the current costs obtained from both Zenon and Memcor as a result of this effort. The Zenon cost ratios for \$/gcpd reflect typical economy of scale ratios as evidenced by the increasing costs associated with lower treatment capacities, while the Memcor cost ratios provided are relatively equal for all flow ranges. Overall, the continued decrease in the overall capital costs of these membrane systems in prior years can be attributed to improvements in membrane technology and inherent changes in the operational mode of the systems. However, in recent months costs for all types of membrane modules (MF, UF, RO) have been increasing due to rising energy and increased market demand.

Relative to Memcor’s chlorine resistant PVdf membrane product, as stated previously, the new membrane material has not been proven at the flow ranges currently under consideration and that direct cost evaluations could not be performed.

3.7 Capital Cost Curves

Capital cost curves were developed for both US-Filter-Memcor and Zenon Process equipment through actual telephone conversations with the manufacturers. The curves follow:

Figure 2 – Zenon Capital Cost Curve





Figure 3 – Memcor Capital Cost Curve



3.8 Operation and Maintenance Cost Curves

The following O&M cost curves were developed using the common cost elements assumed from the HSA updated report and numerous conversations with the membrane manufacturers.

Figure 4 – Zenon O&M Cost Curves





Figure 5 - US Filter-Memcor O&M Cost Curve



3.9 Operation and Maintenance Costs

The O&M costs reflected within the above curves exclude items which were incorporated in the HSA report that were determined to be peripheral from the membrane processes as follows:

- ❑ levee maintenance;
- ❑ treatment of residual solids;
- ❑ building maintenance water control structures;
- ❑ fuel consumption; and
- ❑ sampling and monitoring.

Zenon provided O&M costs for 85 MGD and 170 MGD, while Memcor provided data for 40 MGD. Since both manufacturers indicated that their O&M cost curves are linear, an extrapolation was performed to determine the previously noted graphs.

Chemical costs for Zenon and Memcor were developed utilizing data provided by the respective manufacturers for their processes' chemical requirements. For Zenon's UF membrane, the following chemicals were considered; sodium hypochlorite, MC-1, sodium hydroxide, and sodium bisulfate. For Memcor's MF membrane, the following chemicals were considered; citric acid, liquid chlorine and sodium bisulfate

Common operation and maintenance unit costs for the purposes of comparing O&M costs on an "apples to apples" basis were used. Common costs used in the HSA cost update were adopted wherever available and in collaboration with the membrane manufacturer. These O&M costs are described, as follows:

3.9.1 Labor Costs

The labor costs associated with the Zenon membrane consist of a 24-hour, 7 day per week operation, while the Memcor labor costs provided consist of those costs associated with chemical cleaning labor.

Labor costs were estimated assuming a projected staffing plan for a 24/7 operation and a unit cost of \$30 per hour (includes fringe benefits) per employee.

3.9.2 Spare Parts

Mechanical and Electrical Spare Parts and Supplies are based on 1%/yr. of mechanical and electrical capital costs. The 1% number is the accepted "rule of thumb" used in the membrane industry for these costs.

3.9.3 Coagulant Costs

Coagulant costs were estimated based on the pilot studies chemical dosage. Nominal chemical dosages of ferric chloride (8 mg/L as Fe) for post-BMP and (3 mg/L as Fe) for post-STA application were used to calculate chemical costs. PEER/B&C (August 1999) provided a unit

cost for ferric chloride of \$180 per ton. For post-BMP applications, MF membrane chemical cleaning was estimated to occur every 14 days and for post-STA application, cleaning was estimated to occur every 21 days. Chemical cleanings alternate between citric acid and sodium hypochlorite. One reuse was estimated for the citric acid solution and no reuse of the sodium hypochlorite solution.

3.9.4 Energy Costs

The electrical costs associated with the Zenon membrane have been reduced due to technological advancements and the use of cyclic aeration, while the Memcor membrane provides lower electrical costs due to inherent differences in its configuration (now submerged type).

Electrical energy consumption was estimated based on the estimated treatment plant power consumption and a unit cost of \$0.08 per kWh (SFWMD).





Figure 6 - Relative Energy Requirements for Membrane Processes

Note in the recent bar graph (Figure 6, above) provided by the Electric Power Research Institute the relative difference for energy consumption for MF and UF processes is indicated. The data are shown not to indicate current costs but to show the energy required in kWh/Kgal, one membrane process relative to another. The bar is hardly visible for microfiltration (2) and is indicative of the low energy required for the process.

3.10 Membrane Replacement

The membrane replacement costs for Zenon were obtained from HSA’s cost update report, while the manufacturer provided the Memcor costs. Membrane replacement for both post-BMP and post-STA application is estimated to occur every five years according to HSA. Membrane replacement costs are based on \$10,070 per mgd of nominal treatment plant size (Zenon, 2000). A seven-year membrane replacement cycle was considered by HSA; however, the use of coagulants required for this application may reduce the life of the membranes. In order to remain conservative and not underestimate full-scale O&M costs, a five-year membrane replacement schedule was used by HSA to determine long-term system costs. The Peer Review Team agrees with HSA’s five-year replacement period.

Figure 7 - Comparison of Updated & Peer Review Capital Costs



3.11 Total Annual Operating Cost

The total annual operating cost for Zenon’s membrane are provided as exhibits within the HSA report and have been updated based on information provided by the manufacturer and as reflected in the operational cost curves. Both these costs are based on un-pilot tested UF membranes that have not been pilot tested under the District’s program.

It should be noted that Memcor’s PVdf membrane has not been proven at the flow ranges currently under consideration for this project therefore PVdf membrane costs were not evaluated.

Figure 5 above shows that capital costs have increased over a short period of time. The curves remain flat for most all capacities studied (85-500-mgd).

The following calculations show how the latest membrane O&M cost curves were established. Values were extrapolated as linear for both Memcor and Zenon O&M costs, based on confirmations obtained from the manufacturers. The previous Zenon unit values were obtained from the HSA report for the different flows, with the following exceptions: The O&M cost for a flow of 10 mgd was extrapolated and the cost for a flow of 170 mgd was actually the cost reported for a flow of 165 mgd. The current Zenon values were obtained directly from the manufacturer with the exception of costs for flows of 10 and 500 mgd, which were extrapolated. Memcor costs for flows of 10 through 500 mgd were also extrapolated, and based on a 40 mgd example provided by the manufacturer. The following is a typical breakdown of how O&M costs were determined. The values listed below represent the costs for an 85 mgd flow from the HSA report.

ZENON

Labor	(Unit Cost x Total Hours) 30 \$/hr x 18,720 hr	= \$561,000
Electrical	(Unit Cost x Total Power) 0.08 \$/Kwhr x 8,871,820 Kwhr	= \$709,746
Chemical	(Unit Cost x Dosage) Citric Acid 0.90 \$/lb x 62,475 lb	= \$56,228
	Bleach 0.75 \$/gal x 2,975 gal	= <u>\$2,231</u>
	Sub-Total (Chemical)	= \$58,459
Membrane Replacement	(Unit Cost x Flow) 10,070 \$/mgd x 85 mgd	= \$855,950
Mechanical Maintenance	(Capital Cost x 1%) 20.4 x 0.01	= <u>\$204,000</u>
O&M Cost for 85 mgd		= \$2,389,775/year or \$6,547/day

MEMCOR

Labor	(Unit Cost x Total Hours) 30 \$/hr x 18,720 hr	= \$561,000
Electrical	(Unit Cost x Total Power) 0.08 \$/Kwhr x 913,277 Kwhr	= \$73,062
Chemical	(Unit Cost x Dosage) Citric Acid	

	0.90 \$/lb x 75,098 lb	= \$67,588
Liquid Chlorine	0.11 \$/lb x 85,455 lb	= \$9,400
Sodium Bisulfite (dechlorination)	0.35 \$/lb x 102,517 lb	= <u>\$35,881</u>
Sub-Total (Chemical)		= \$58,459
Membrane Replacement (Unit Cost x Flow)	14,811 \$/mgd x 40 mgd	= \$592,440
Mechanical Maintenance (Capital Cost x 1%)	0.289 \$/gpd x 40,000,000 gpd x 0.01	= \$115,600
O&M Cost for 40 mgd		= \$753,360/year
		or \$2,064 /day

Figure 8 - Comparison of Current Zenon UF & Memcor MF O&M Costs





Figure 9 - Required Footprint For Memcor CMF-S MF Process



3.12 Industry Trends

Treatment plants utilizing membrane technologies benefit from the following:

- Membrane plants consistently produce superior quality water versus conventional technologies
- They provide a hedge against future more stringent regulations
- Require less operator attention, and
- Are aesthetically more pleasing

The development of membrane process costs since the first municipal RO membrane plant came on line in Florida in 1971 has been merging towards comparable conventional treatment process costs. An example of this trend is the costs for conventional lime softening versus membrane softening. Membrane softening has replaced conventional lime softening in Florida since it was first proposed on a large scale in 1988. MF and UF will undoubtedly replace conventional filtration in time. Seawater RO, once thought to be cost prohibitive is now at its lowest cost in history. For example, at Tampa Bay Water the water developer has been contracted to produce potable water from Tampa Bay at a cost of \$1.71/Kgal.

This trend toward lower costs or merging of costs is more readily noticed when costs are compared on a beneficial cost ratio analyses basis or in a matrix type evaluation. Some project cost components do not have intrinsic fixed value and common sense judgment factors need to be used to determine worth.

3.13 Residuals Management

HSA's updated report states on page 5-9, Peer/B&C (August 1996) estimated a base capital construction cost for residual solids treatment and disposal facilities of \$20,000/mgd of average daily design flow. Further, this cost was developed assuming thickening in settling ponds followed by underground injection on an adjacent dedicated land disposal site. The chemical feed dosages for the MF would be clearly less than that of the chemical treatment technologies discussed in the B&C document. The lower dosages for MF would reduce the cost to \$7,500/mgd. For the same reason the B&C 1996 estimated O&M costs of \$1,200/mgd were reduced to \$450/mgd by HSA.

HSA's updated report on page 5-16 calls for land application of MF residual solids in the vicinity of the MF treatment facility. HSA states this would be the most cost effective solution however dewatering and transport to an approved landfill would also be a technically feasible option, but more expensive. Industry dewatering would employ one of the following methods; belt press, filter press, vacuum filtration or centrifugation.

Typically, ultimate disposal of water plant residuals is accomplished by:

- discharge to sanitary sewers;
- hauling to landfill;
- on-site disposal; and/or
- recovery of by-products.

By-product recovery of water treatment plant sludge has been accomplished, sometimes successfully, internationally through:

- brick making;
- augmentation as a soil conditioner; and/or
- chemical recovery.

Site-specific studies and pilot testing are recommended for proving any by-product recovery method.

Table 1 - Chemical Dosages for Post-BMP Processes Using Ferric Chloride

Process	Ferric Chloride Dosage(mg/l)
Chemical Treatment/High Rate Sedimentation Post-BMP North Site	40
Microfiltration Post-BMP	8

Table 2 - Pounds of Chemicals Used By Post-BMP Processes

Process	Ferric Chloride (lbs/mg)	Polymer (lbs/mg)
Chemical Treatment/High Rate Sedimentation Post-BMP North Site	954.1	4,017.0
Microfiltration Post-BMP	190.8	Not tested

Table 3 - Comparison of Chemical Costs for Post-BMP Processes

Process	Post-BMP (\$/million gallons)
Chemical Treatment/High Rate Sedimentation Post-BMP North Site	145.95
Microfiltration Post-BMP	21.20

As can be seen from Tables 1 through 3 above, chemical dosages, pounds of chemicals, chemical costs and subsequent residuals disposal costs for ferric chloride sludge generated by the chemical treatment/high rate sedimentation process will be much greater than for the MF process.

We agree with HSA's assessment that local land spreading would appear to be the most cost effective residuals disposal method.

3.14 Conclusions

HSA's updated report cites Zenon's cost data as shown in Table 5.9 of the updated report. These costs were for UF systems although Zenon no longer manufactures the microfiltration M-150 membrane pilot tested by CRA. The costs obtained by the Peer Review Team from Zenon yielded even higher costs than those in Table 5.9 reported in the HSA report. In recent months costs for all membrane modules (MF, UF, RO) have been increasing due to rising energy costs and market demand.

The Peer Review Team recommends the District use the capital cost curve for US Filter-Memcor CMF-S Submerged membrane system. The latest US Filter-Memcor costs are elevated 12 to 14% higher than the updated Zenon costs shown in Table 5.9. The polypropylene membrane material used in the CMF-S system is the same membrane material used in the CMF modules tested by CRA with satisfactory results. The difference in the two operating systems, CMF versus CMF-S is in the device configuration. The system pilot tested by CRA was in the enclosed cartridge configuration while the latest recommended configuration is in the submerged mode.

Table 4 - Cost Comparison of UF, MF and CT-SS Processes for Post-BMP Flows

Post-BMP Flows (mgd)	450	315	230	240	165	125
Table 5.9	\$108,000,000	\$75,600,000	\$55,200,000	\$57,600,000	\$39,600,000	\$30,000,000
UF						
Memcor	\$120,150,000	\$85,995,000	\$64,630,000	\$66,960,000	\$47,025,000	\$36,000,000
CT-SS	\$62,000,000	\$47,000,000	\$34,000,000	\$36,500,000	\$27,500,000	\$21,500,000

Table 5 - Cost Comparison of UF, MF and CT-SS Processes for Post-STA Flows

Post-STA Flows (mgd)	500	305	225	160	110	85
Table 5.9	\$120,000,000	\$73,200,000	\$54,000,000	\$38,400,000	\$26,400,000	\$20,400,000
Memcor	\$133,500,000	\$83,570,000	\$63,000,000	\$45,440,000	\$31,680,000	\$24,480,000
CT-SS	\$67,000,000	\$44,000,000	\$33,000,000	\$25,000,000	\$19,800,000	\$16,000,000

In the above tables (Tables 4 and 5), the updated report costs from HSA's Table 5.9, Memcor costs generated by the Peer Review, and the CT-SS Peer Review capital costs are compared for various flow ranges. It is interesting to note as the flows are diminished the capital costs move closer for the two technologies. Examination on a present worth basis comparing MF and CT-SS costs should reveal an optimum plant capacity at which MF may be the most cost effective process to use.

The updated capital cost estimates by HSA were verified to be sufficient for the engineering budgetary cost estimate since their accuracy range was within +30% to -15%, which is in accordance with the norms developed by the American Association of Cost Engineers.


Table 6 - O&M Cost Comparison for Post-BMP and Post-STA Systems

	450 mgd Post-BMP (\$/Kgal)	500 mgd Post-STA (\$/Kgal)
HAS Updated Report Zenon	.05	.04
Current Zenon	.10	.10
Current Memcor	.06	.06

However, based on a comparison of HSA's costs in Table 5-12, O&M costs (without levee maintenance, residuals solids management, sampling and monitoring), on a \$/Kgal basis, the current O&M costs provided by the US-Filter Memcor and Zenon are higher. The Peer Review Team recommends using the current Memcor MF O&M costs which when compared to HSA's latest costs are more conservative but within the plus 30% estimate guidelines developed by the American Association of Cost Engineers for most flow ranges considered in the study.

APPENDIX A

Basic US Filter-Memcor CMF System



The MF system that was tested by CRA was the Memcor CMF system described in the following paragraphs. The heart of the polypropylene Continuous Microfiltration (CMF) system consists of hollow fiber microporous membranes. These membranes are approximately 0.5mm in diameter, and are encapsulated into a bundle to form a filter module. The filter modules housing the membranes are modular in design, and are connected by an interlocking mechanism that reduces external plumbing requirements.

During normal operation of the US Filter-Memcor CMF system, the feed passes from the outside of the membrane (from the module shell) into the center (lumen) and exits as filtrate. Suspended solids and microorganisms are collected on the outside surface of the hollow fiber. Typical system feed pressure is 25 to 35 psid (170 to 240 kPa). The normal operating differential pressure for the membrane is 5 to 30 psid (35 to 210 kPa), with an average initial differential pressure loss of 5 to 8 psid (35 to 55 kPa).

The gas backwash utilized by the process, is a self-cleaning regime for the cleaning of hollow fiber membranes. Compressed air is used to perform a backwash, with air being introduced into the filtrate side of the system, and released through the walls of the hollow fiber. Accumulated solids are flushed from the membrane surface using feed water. Filtrate is not used to backwash the membranes.

US Filter-Memcor CMF systems have been proven to be effective in the removal of particles greater than 0.2 micrometers (which is the absolute pore size of the membrane), colloidal particles, fecal bacteria and enteric viruses, *giardia lamblia*, *cryptosporidium* cysts, heavy metal particulates and their hydroxides, algal blooms, and yeast cells enabling these systems to meet current and future requirements. The systems also have a number of membrane integrity diagnostic facilities that monitor the system integrity and provide continuous filtrate quality assurance.

The core component of a CMF filtration system is the microporous hollow fiber membrane that forms the filtration barrier. The fibers are bundled together to form a submodule. The submodule is housed in a Module. The module is constructed of molded nylon components, and has been designed to fit together with other modules into a module block or a. module blocks are fitted to a frame and connected with piping, valving and electrical and pneumatic controls to construct a CMF unit.

Groups of CMF units may be connected together in a row to form a CMF train. The units in a train share common ancillary equipment such as manifolds, backwash disposal, air supply, chemical cleaning system and controls.

The CMF-S submerged membrane system described in the next section was not available at the time CRA began pilot testing. The new CMF-S system is, according to Memcor technical staff, a later generation product more suitable to this application. Like the Zenon ZeeWeed® UF membrane system, the CMF-S is a submerged system.

Basic Overview of the Latest US Filter-Memcor CMF-S Microfiltration System

As engineers and owners gain microfiltration experience and with the declining cost of membrane technology, the trend is to design larger microfiltration plants. However, according to Memcor, incorporating considerations for economy of scale, there is a point above 15-mgd where supplying multiple skidded systems is not as economical. The CMF-S system addresses this opportunity with a pre-engineered modular membrane system designed to be submerged into built on-site rectangular concrete tanks.

CMF has been an established and proven technology and according to the manufacturer they have more than 700 CMF systems around the world and during this decade they further state CMF capital and operating costs have dropped by over 50%. This trend continues in the next step of the CMF's evolution, a submerged CMF, or CMF-S. US Filter-Memcor researched and developed the submerged membrane system over the past two years. The aim was to reduce capital costs, simplify and scale up the microfiltration process for full-scale applications. After running over a half dozen small-scale trials on a range of feed waters, the design was validated. The first commercial plant was commissioned in August 1998 at Dalesford, Victoria, Australia.

Submerged Microfiltration Membrane System

Courtesy of US Filter Memcor

The CMF-S uses a membrane with a 0.2-micron pore size and demonstrates up to 6-log removal of *Giardia* and *Cryptosporidium*. A vacuum pump draws water through the membrane fibers of sub-modules submerged in the open top filter tanks. The fibers are the same polypropylene material as those used in the conventional CMF process, but the Memcor CMF-S operates under vacuum, so the maximum driving pressure is only 85-100kPa. This lower pressure limit is not the disadvantage it first appears to be because filter cake characteristics improve at lower pressures. Compared against earlier versions of CMF, operation of the submerged system has according to the manufacturer, elsewhere demonstrated the following:


- ❑ Fluxes 80-95% of CMF
- ❑ The same backwash efficiency and backwash intervals
- ❑ The same cleaning efficiency and CIP intervals
- ❑ The same membrane integrity

Basic Overview of the Zenon UF Membrane Technology

The ZeeWeed® membrane module's features are as follows:

- ❑ Can accommodate coagulant additions such as Ferric Chloride
- ❑ Oxidant resistant and chlorine tolerant
- ❑ Over 2.5 log removal of viruses
- ❑ NSF 61 certified ultrafilter

ZeeWeed® water treatment is a proprietary Zenon process technology that can produce high quality water by drawing raw water through immersed UF membrane modules. The ZeeWeed® "Outside-In" hollow-fiber membranes form an absolute barrier to particulate, including *giardia* cysts and *cryptosporidium* oocysts. The ZeeWeed® ultrafiltration membrane can remove a large percentage of impurities. This includes certain viruses, which are removed by a combination of adsorption onto the solids in the process tank and by membrane filtration.



The membranes operate under a slight vacuum created within the hollow membrane fibers by a permeate pump. Pretreated water (after ferric chloride addition) is further treated as it is drawn through the membranes, enters the hollow fibers and is returned less the major portion of the phosphorous to the Everglades system. Air flow is introduced at the bottom of the membrane modules to create turbulence which scrubs and cleans the outside of the membrane fibers allowing them to operate at a high flux. The cyclic aeration provided also oxidizes iron and organic compounds, resulting in a treated water quality which is greater than that provided by ultrafiltration alone.



Courtesy of Zenon
Environmental

As stated above the UF system would be effective at removing phosphorous from water. Coagulant would be injected into the water as was in the CRA pilot tests to allow the formation of floc particles, which only need to be larger than the membrane pores to be rejected.

UF membranes can effectively replace both clarifier and granular media type filters found in a conventional water treatment plants resulting in easier control for plant operators.

The membranes are immersed directly in the process tank and are under a slight vacuum. High suspended solids concentrations do not foul the membranes or cause excessive backpulsing frequency and therefore, avoiding the loss of productivity.

These membranes have the additional benefit of being chlorine resistant up to concentrations of 1,000 mg/l. Therefore, influent water can be pre-chlorinated if deemed necessary. This type of membrane process can consistently produce high quality water as the membranes are less subject to stress, pressurization or rapid pressure fluctuations. Membrane cleaning by backpulsing is achieved by reversing the permeate flow and backwashing the fiber's lumen with permeate at low pressure. The small variations in operating pressure occur smoothly over relatively long periods so that at no time is the membrane stressed.

Operational Microfiltration & Ultrafiltration Facilities Water & Wastewater Treatment Facilities > 100,000 gpd Project Name	Owner	Startup	Feedwater	Capacity (gpd)
	Whitebull Water Treatment Works	North West Water	1997	Groundwater
Koper (Slovenie)	Koper (Slovenie)	12/1/1997	Groundwater	9,200,000
Winnick Water Treatment Works	North West Water	8/1/97	Groundwater	4,230,000
Chilhowie WTP	Village of Chilhowie VA	7/20/1999	Groundwater	2,500,000
Spectacle Pond Well Treatment	Littleton, MA	4/1/1998	Groundwater	1,500,000
Rocco Farm Foods	Rocco Farm Foods	1/1/96	Groundwater	1,500,000
Fontgombault, France	Lyonnaise des Eaux	5/10/93	Groundwater	1,321,000
Bernay, France	Lyonnaise des Eaux	10/1/93	Groundwater	872,000
La Filliere, France	Lyonnaise des Eaux	2/1/93	Groundwater	528,400
Sauve, France	Lyonnaise des Eaux	6/1/91	Groundwater	502,000
Douchy, France	Lyonnaise des Eaux	8/1/89	Groundwater	320,000
Urzy, France	Lyonnaise des Eaux	3/1/93	Groundwater	291,000
Gracay, France	Lyonnaise des Eaux	6/1/90	Groundwater	190,000
Chatel-Gerard, France	Lyonnaise des Eaux	6/1/93	Groundwater	174,000
Bristol Myers Squibb GW Remediation	Bristol Myers Squibb	8/1/94	Groundwater	168,000
Charcenne, France	Lyonnaise des Eaux	9/1/92	Groundwater	158,000
Saint-Jean D'Arvey, France	Lyonnaise des Eaux	1/1/94	Groundwater	158,000
Douchy I	Lyonnaise des Eaux	3/1/95	Groundwater	110,000
Dungannon WTP	Dungannon, Town of	12/1/98	Groundwater	70,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Huntington Water Treatment Works	North West Water	9/1/96	Surface Water	20,000,000
Heemskerk	N.V. PWN Water Supply Company of North Holland	4/99	Surface Water	18,500,000
Lausanne, Switzerland	Lausanne, Switzerland	6/1/99	Surface Water	17,200,000
Vigneux-sur-Seine WTP Jan. 1998 Article Dec. 1997 Article Oct. 1997 Article	Lyonnaise des Eaux	10/13/97	Surface Water	14,500,000
Kenosha Water Plant (Project Description) 1996 Article May, 1999 Article Memcor -- Kenosha Tour 99	Kenosha, City of	12/22/98	Surface Water	14,000,000
Ennerdale Water Treatment Works	North West Water	2/15/2000	Surface Water	11,900,000
Manitowoc, WI	City of Manitowoc, WI	5/15/99	Surface Water	11,000,000

Joyce Road Water Treatment Plant	Tauranga District Council, New Zealand	12/97	Surface Water	9,775,400
Industrial Business Park Industrial Water Production Facility (1998 News Account)	Bexar Metropolitan Water District	1/2000	Surface Water	9,000,000
Cornhow Water Treatment Works	North West Water	1998	Surface Water	8,450,000
Collingwood, Ontario (Project Description) (Zenon Article)	Collingwood Public Utilities Commission	Train 1 since 7/97, Trains 2 thru 5 since 12/98	Surface Water	7,600,000
Apie Saint-Cassien Plant	Lyonnaise des Eaux	1/1/97	Surface Water	7,500,000
Kamole Weir WTP M&E Description Alt. Description	Maui Water (County of Maui)	5/1/98	Surface Water	7,200,000
Loch Lomond Temporary MF Facility	City of Thunder Bay, Ontario	11/8/98	Surface Water	7,000,000
Marquette MI (May 1998 Award) (1998 Abstract) (9/98 Article)	Marquette, City of	10/1/97	Surface Water	7,000,000
Scottsdale Water Campus (water)	Scottsdale, AZ	2/1/99	Surface Water	6,000,000
Saratoga Water Treatment Plant (Description)	San Jose Water Co.	3/1/94	Surface Water	5,000,000
Westside Water Treatment Plant	Cucamonga County Water District	5/1/97	Surface Water	4,000,000
Brooklyn Naval Shipyard		2/1/99	Surface Water	3,450,000
Ft. Lupton-Hudson WTP	Ft. Lupton, City of	12/1/96	Surface Water	3,000,000
Lahaina WTP, Lahaina Maui	Maui Water (County of Maui)	5/1/97	Surface Water	2,700,000
Dayton WTP	Dayton, VA	4/1/99	Surface Water	2,200,000
Mackinac Island (Abstract)	Mackinac Island	5/1/98	Surface Water	2,000,000
Greytown, New Zealand	Greytown, NZ	4/1/99	Surface Water	2,000,000
NUANNU Lower Aerator	Honolulu HI Board of Water Supply	3/1/99	Surface Water	2,000,000
Giles County PSA	Giles County PSA, Pembroke VA	7/1/99	Surface Water	2,000,000
Foxwoods Casino	Mashantucket Pequot Tribe	2/1/96	Surface Water	1,800,000
Iao Ditch, Maui	Maui Water (County of Maui)	5/1/97	Surface Water	1,800,000
Olinda WTP, Maui	Maui Water (County of Maui)	5/1/98	Surface Water	1,700,000
White Plains, NY	White Plains, NY	1/1/99	Surface Water	1,600,000
Sioux Lookout	Sioux Lookout--First Nation, Ontario	11/1/98	Surface Water	1,400,000
La Nive, France	Lyonnaise des Eaux	5/1/92	Surface Water	1,321,000
Amherst Water System	Amherstview, Ontario	4/1/98	Surface Water	1,300,000

Wallace, Idaho USDA Success Story (PDF)	East Shoshone County Water District	1998	Surface Water	1,200,000
Anthem Water Campus	Maricopa County, Arizona	9/1/98	Surface Water	1,000,000
CAP Water Plant	Scottsdale, AZ	9/1/94	Surface Water	1,000,000
New Market VA	New Market, Town of	8/5/98	Surface Water	1,000,000
Olivenhain Demo Facility Press Release	Olivenhain Municipal Water District	9/1/99	Surface Water	1,000,000
Project Description				
Douglas County	Douglas County, Virginia	5/1/97	Surface Water	960,000
Coles Run WTP, Verona VA	Lower Brule Community	11/15/99	Surface Water	960,000
Lower Brule Reservation WTP		1/1/98	Surface Water	960,000
Kisima Industrial Site	NV Water Company, Netherlands	2/1/99	Surface Water	951,000
Nagambie Water Treatment Plant (EIDN Project Description) (Press Release)	Goulburn Valley Water, Victoria Australia	8/5/94	Surface Water	925,000
Avoriaz, France	Lyonnaise des Eaux	11/1/93	Surface Water	898,000
Mullan, Idaho	East Shoshone County Water District	1998	Surface Water	800,000
Estevan Power Station	Saskpower	5/1/97	Surface Water	720,000
Macao UF Plant	Macao Water Supply LTD	6/1/91	Surface Water	690,000
Meredith Water Treatment Plant	Barwon Water, Victoria Australia	6/1/1993	Surface Water	660,500
Rothersey, NB	Rothersey, New Brunswick	6/1/96	Surface Water/Groundwater	600,000
Crow Creek Reservation, Ft. Thompson Community	Aberdeen Area Indian Health Service	8/15/99	Surface Water	500,000
Clyde Potts WTP, Morris, New Jersey	Southeast Morris County Munic. Utilities Authority	8/1/97	Surface Water	500,000
Kodak, Australia	Kodak	1/1/94	Surface Water	500,000
Lincoln Memorial University	LMU, Harrowgate TN	1/1/96	Surface Water	500,000
Argyl Diamond Mine, Australia	Argyl Diamond Mine	1/1/92	Surface Water	432,000
Rural Retreat	Rural Retreat, Town of	2/1/98	Surface Water	420,000
Marulan WTP	Mulwaree Shire Council, New South Wales, Australia	8/1/98	Surface Water	396,000
Barrow Water Systems Upgrade	Barrow Utilities & Electric Cooperative, Barrow Alaska	6/1/99	Surface Water	360,000
McKinley Paper Mill, Prewitt, NM	McKinley Paper Mill	6/1/94	Surface Water	360,000
God's Lake	God's Lake--First Nation, Manitoba	8/1/98	Surface Water	350,000
Wainwright Alaska	Wainwright, City of	8/1/97	Surface Water	324,000
Shamattawa -- First Nation	Shamattawa--First Nation, Manitoba	11/1/98	Surface Water	300,000
Pardee Recreation Area	East Bay MUD	1996	Surface Water	300,000

Birregurra Water Treatment Plant	Barwon Water , Victoria Australia	6/1/98	Surface Water	264,200
Echo Bay, Lake Mead	National Park Service	3/1/99	Surface Water	259,000
Overton Beach, Lake Mead	National Park Service	3/1/99	Surface Water	259,000
Beausoleil First Nation	Beausoleil First Nation, Ontario	5/1/99	Surface Water	240,000
Pine Brook Water District WTP	Pine Brook Water District, Boulder CO	4/1/97	Surface Water	240,000
Linwood MWD	Linwood Metropolitan Water District	12/1/98	Surface Water	216,000
Weyerhaeuser	Weyerhaeuser, Alberta	7/1/95	Surface Water	200,000
Edinburg VA	Edinburg	6/1/98	Surface Water	180,000
Water Treatment Improvements Project	Bolin Community Public Utility District	2/1/96	Surface Water	160,000
Shoal Lake	Shoal Lake--First Nation, Ontario	10/1/98	Surface Water	150,000
Cadbury Schweppes, Australia	Cadbury Schweppes	1/1/94	Surface Water	144,000
San Bernadino, CA National Forest	US Forest Service	6/1/93	Surface Water	144,000
Strawberry WTP	El Dorado Irrigation District	11/1/94	Surface Water	132,000
Noble County, Lucien OK	Noble County	11/1/97	Surface Water	120,000
Waiawa Correctional Facility	Hawaii Dept of Public Safety	12/1/96	Surface Water	120,000
Perth Way Treatment Plant	Inverness Public Utilities District	4/1/96	Surface Water	120,000
Tomsbrook	Tomsbrook	7/1/97	Surface Water	120,000
West Jefferson WTP	West Jefferson, Town of	9/1/98	Surface Water	120,000
Seri Kembangan WTP	Transwater Corporation, Malaysia	4/1/98	Surface Water	120,000
Beverly Beach State Park	Oregon State Parks	5/1/99	Surface Water	115,000
New Rochelle WTP	New Rochelle NY, Town of	10/1/92	Surface Water	108,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Eindhoven	NV Nutsbedriff Regio Eindhoven	5/1/97	Backwash Water	634,000
Rocco Farm Foods Backwash Recovery	Rocco Farm Foods	1/1/96	Backwash Water	160,000
Douglas County Backwash Recovery	Douglas County	5/1/97	Backwash Water	160,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Westview Water Reclamation Facility	Powell River, BC	10/1/98	Wastewater (Raw)	2,000,000
Kaha Egypt	Kaha, Egypt	7/1/98	Wastewater (Raw)	2,000,000
El Obour Egypt	El Obour, Egypt	9/1/98	Wastewater (Raw)	1,320,000
Anthem Water Campus	Maricopa County, Arizona	10/1/98	Wastewater (Raw)	1,000,000
Arapahoe CO	Arapahoe, CO	8/1/98	Wastewater (Raw)	1,000,000
Porlock MBR Facility	Wessex Water	2/1/98	Wastewater (Raw)	500,000
Oakwood, NJ	Oakwood, NJ	2/1/98	Wastewater (Raw)	350,000

Mt. Washington Ski Resort	Mt. Washington, BC	11/1/96	Wastewater (Raw)	300,000
Hidden Meadows NJ	Hidden Meadows, NJ	5/1/98	Wastewater (Raw)	104,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Milton	Milton, Ontario	6/1/97	Wastewater (Primary)	530,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Mobil Boiler Feed project	West Basin Municipal Water District	8/1/98	Wastewater (Unfiltered Secondary)	3,800,000
Clean Water Revival	Dublin San Ramon Services District	12/15/98	Wastewater (Unfiltered Secondary)	2,940,000
Barrier Project (Phase II Expansion) USBR Description	West Basin Municipal Water District	6/1/97	Wastewater (Unfiltered Secondary)	2,940,000
Cronulla Membio Facility	Cronulla Australia	11/1/92	Wastewater (Unfiltered Secondary)	994,000
Eraring Power Station, Lake Macquarie, New South Wales Case Study #2	Pacific Power Corporation	3/1/96	Wastewater (Unfiltered Secondary)	920,000
Blackheath, Australia	Blackheath Australia	1/1/91	Wastewater (Unfiltered Secondary)	900,000
Key Colony WWTP	Key Colony, Florida Keys	1/1/99	Wastewater (Unfiltered Secondary)	850,000
OCWD MF Demo Project #1	Orange County Water District	8/1/94	Wastewater (Unfiltered Secondary)	792,000
LeHigh Florida	Lehigh, FL	10/1/98	Wastewater (Unfiltered Secondary)	750,000
OCWD MF Demo Project #2	Orange County Water District	3/3/99	Wastewater (Unfiltered Secondary)	720,000
Mount Barker STEDS Effluent Treatment Plant	District Council of Mt. Barker, NSW, Australia	1998?	Wastewater (Unfiltered Secondary)	616,000
Orascum Egypt	Orascum Egypt	9/1/97	Wastewater (Unfiltered Secondary)	530,000
Margaretville STP	New York City	4/1/99	Wastewater (Unfiltered Secondary)	480,000
Grahamsville STP, Neversink NY	New York City	4/1/97	Wastewater (Unfiltered Secondary)	360,000
Ganges, BC Phase II Upgrade	Ganges, BC	9/1/98	Wastewater (Unfiltered Secondary)	211,000
Ganges, BC Phase I	Ganges, BC	12/1/96	Wastewater (Unfiltered Secondary)	90,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Scottsdale Water Campus (wastewater)	Scottsdale, AZ	2/1/99	Wastewater (Filtered Secondary)	10,000,000
Carson RWTF	West Basin Municipal Water District	1/2000	Wastewater (Filtered Secondary)	5,880,000
Tannersville WTF	New York City	8/1/98	Wastewater (Filtered Secondary)	2,000,000
Grand Gorge WTF	New York City	8/1/98	Wastewater (Filtered Secondary)	1,250,000

Pine Hill WWTP	Pine Hill, NY	11/1/98	Wastewater (Filtered Secondary)	1,250,000
Livermore AWRP	Livermore, City of	2/1/97	Wastewater (Filtered Secondary)	880,000
Project Name	Owner	Startup	Feedwater	Capacity (gpd)
Chandler Intel Wastewater Treatment (Ionics Project Description) (Other Project Description) B&V 1996 Writeup June 1996 Article	Chandler, City of	11/1/97	Industrial Wastewater	1,728,000
Zinc Nacional	Zinc Nacional (Mexico)	12/1/98	Industrial Wastewater	288,000

Courtesy of © [Fluid Knowledge](#), 1998 & 1999 & 2000. Latest Update 1/14/2000
 Feel free to cite the information provided here, however please reference the source as:

Geselbracht, J. J., (2000), "Operational Microfiltration & Ultrafiltration Water & Wastewater Treatment Facilities", Fluid Knowledge, <http://www.fluidknowledge.com/fksite/links/mfprojects>, January 14.

GLOSSARY OF FILTRATION TERMS (Courtesy of US Filter-Memcor)

Acidity

The quantitative capacity of aqueous solutions to react with alkalis.

Alkalinity

The quantitative capacity of aqueous solutions to react with acids.

Backwash

Reversed flow through a filter medium to remove filtered solids.

Break Tank

Storage tank at atmospheric (a break in head pressure) pressure from which feed is drawn prior to filtration.

Bubble Point

The pressure at which air first passes through a wet membrane; the path being the channel of greatest pore size.

Cartridge

An assembly of filtration media in a housing.

Caustic

A Sodium Hydroxide (NaOH) solution.

Center Tube

The nylon or stainless steel tube which forms the main shell of an M10 class CMF module.

CIP

Clean-in-place. A method whereby a filter medium can be chemically cleaned to restore performance without requiring removal from the system.

Cleaning Agent

An agent used to soften, disintegrate, or dissolve contaminants lodged in a filter.

CMF

Continuous Microfiltration. Memcor's microfiltration product, which uses a gas backwash to allow continuous operation on feed streams of varying quality, is a CMF system.

Coliforms

A group of bacteria which are used as indicator organisms in various standards of hygiene for drinking water and wastewater treatment.

Concentrate

The non-filtered stream leaving a crossflow filter system. Also called Return, Recycle, Recirculation, or Reject.

Compaction

The reduction in thickness of a filter medium as a result of applied filtration pressure (TMP).

Cross Flow Filtration

Method of filtration where the feed stream flows parallel to the surface of the filter medium to minimize fouling. Only a percentage of the feed passes through the filter medium.

DAF Test

Diffusive Air Flow Test. A high-resolution test for detecting membrane integrity to one part in 10^7 . It measures the amount of air that is diffused through a wetted membrane.

Deadleg

An area of the pipework in which process fluid may stagnate.

Direct Filtration

A method of filtration whereby the feed stream is fed directly to the filtration media. All the feed passes through the membrane. No crossflow is used; therefore, feed flow and filtrate flow are balanced during filtration.

Dynamic Membrane

A transient membrane formed on the surface of an established membrane by solids filtered from the feed stream. Sometimes called a filter cake.

End Manifold

A molded plastic component which provides a simplified means of connecting module banks together to form a module array, while maintaining separation of feed and filtrate.

Feed

The raw supply liquid to the filtration unit.

Fiber

More correctly called the Hollow Fiber Membrane. A bundle of thousands of fibers is used in each Memcor® module.

Filtrate

The end product of the filtration process; i.e., liquid exiting the filtrate outlet.

Filtrate Flow Rate

The instantaneous volume per unit time of filtrate produced by a system, typically measured on a filtrate flowmeter.

Filtrate Flux

The rate of filtrate flow as expressed per unit of filtration area (liters/meter sq. hour).

Filtrate Shut-off Valve

The device used to isolate filtrate flow from a single module. It is a built-in feature of the Memcor® M10 class module.

Filtrate Side

That part of a system which carries filtrate flow, including fiber lumens and all filtrate-carrying manifolds and pipework

FTU

A measure of turbidity equal to NTU.

Hardness

The concentration of polyvalent cations in water.

Head

The manifolded headpiece of the CMF module.

Hydrophilic

Water-loving. Easily wetted with water.

Hydrophobic

Water-aversive. Not easily wetted with water.

kg

Kilogram - unit of mass. Consists of 1000 grams or 2.2 lbs.

kPa

Kilopascal - a unit of pressure. 100kPa = 14.75 psi or 1 atmosphere.

Lumen

The axial hole through the center of a hollow fiber membrane.

Lumen Side

Same as [Filtrate Side](#) for outside to inside filtration as used by Memcor's CMF process.

M10

Nomenclature for the filter modules used in Memcor® CMF systems. Membranes housed in an M10 module have an equivalent surface area of approximately 10m² or more.

Membrane

A porous barrier filtration medium. It may be flat (e.g. R.O.), or a hollow fiber (e.g. Memcor® CMF).

Membrane Test

A process, based on membrane bubble point characteristics, for testing the integrity of the membranes used by the Memcor® CMF system.

Memclean®

Proprietary chemical solution used to clean microfiltration membranes and systems.

Microfiltration

Membrane filtration of a liquid which removes particles in the range of 0.1 to 1.5 microns. Memcor® membranes have a nominal pore size of 0.2 microns.

Module

An assembly of hollow fiber membranes in a single pressure vessel or housing with a head manifold at each end containing separate feed and filtrate connections.

Module Array

Multiple module banks connected by end manifolds to form a block of filtration modules. A ninety-module array consists of fifteen banks of 6 modules each.

Module Bank

Multiple single modules connected together in a row with end manifolds.

Nephelometer

An instrument which uses scattering light to measure turbidity in a liquid. Commonly known as a turbidimeter.

NTU

Nephelometric Turbidity Unit. Unit of turbidity (lack of clarity) obtained by measuring scattering of light in a liquid.

Osmosis

The natural transport of water through a semi-permeable membrane which separates two solutions of different solute concentration.

Outer Sleeve

The threaded retainer which holds the head to the center tube of an M10 CMF module.

Permeate

The product, or filtrate, of Reverse Osmosis or ultrafiltration.

pH

Measurement of acidity (<7) or alkalinity (>7). The logarithm of the reciprocal of hydrogen ion concentration in an aqueous solution.

PLC

Programmable Logic Controller. Used to control the functions of a Memcor® CMF system.

Pore

Small interconnecting passage through the membrane. The size and irregular path of a pore determines the removal rating of a membrane.

Pore Size

The equivalent diameter of the smallest part of any channel through a membrane.

Potting

The securing material or adhesive that seals the filter material in a cartridge.

Prefilter

A device installed upstream of the main filtration process to remove large solids.

PSI

Pounds per square inch. A unit of pressure. 1 PSI = 6.78 kPa.

Return Flow

The concentrate which is returned to the head of the process for further processing.

Rewetting

The process of refilling the pores of a hydrophobic membrane with liquid.

Sanitizing Agent

An agent introduced into a system to kill organisms and prevent the growth of organisms.

Scale

The deposits, usually salts, created as a solution increases and exceeds its solubility limit, that builds up on the filter media.

Shell

The outer tube encasing the hollow fibers in a module.

Shell Side

The part of a CMFsystem which carries feed flow, including module casings, feed manifolds, and feed and recirculation pipework.

Sub Module

The replaceable bundle of hollow fiber membranes contained in an M10 class module.

TDS

Total Dissolved Solids. May be used as an indication of the level of contamination of water.

TOC

Total Organic Carbon. May be used as an indication of the level of contamination of water. Measures the CO₂ produced from organics when a water sample is atomized into a combustion chamber.

TMP

Transmembrane Pressure. The average pressure across the membrane.

Turbidity

Non-clarity caused by fine suspended particles. Defined by measurement of scattering light through a sample.

Ultrafiltration

A pressure-driven membrane process which rejects large molecules in the range of approximately 0.005 to 0.1 microns.

Wetting

The process of filling pores of a hydrophobic membrane with water. Typical methods include use of alcohol as a wetting solution, or high pressure to drive air out.